

AUG 13 1991

ORDINANCE #25-2

AMENDMENT TO ORDINANCE #25-1

AN ORDINANCE AMENDING ORDINANCE #25-1 ADOPTED THE 3rd DAY OF JULY 1990, AMENDING SAID ORDINANCE TO IMPOSE WATER CONSERVATION PERFORMANCE STANDARD FOR PLUMBING FIXTURES AND FITINGS AND REVISING THE REQUIREMENTS FOR THE USE OF OUTSIDE TOILETS.

The Supervisors of Westfall Township, County of Pike and Commonwealth of Pennsylvania, hereby enact and ordain as follows:

SECTION 1. The aforesaid Ordinance is hereby amended as follows:

SECTION 5. MINIMUM REQUIREMENTS:

(d) All plumbing specifications shall meet the regulations of all existing laws and requirements of any applicable governmental body, whether the same be an agency, department or commission of the United States of America, Commonwealth of Pennsylvania, County of Pike, this Township or any other agency, department or commission with jurisdiction appertaining.

(h) The construction or erection of outside toilets is prohibited. However, the temporary use of portable retention tanks or portable chemical toilets at construction sites or at sites of public gatherings or entertainment shall be permitted, upon application therefor being made to the Township Sewage Enforcement Officer under and in accordance with the requirements of the Rules and Regulations promulgated by the Pennsylvania Department of Environmental Resources. No such portable retention tanks or portable chemical toilets shall be used at any construction site for longer than the lesser of the actual construction period or six (6) months and at any site of public gatherings or entertainment for longer than the lesser of the permitted duration of such public gathering or entertainment or ten (10) days. Exceptions may be granted by the Board of Supervisors to the aforesaid periods of permitted use on showing of necessity therefor by the applicant.

(i) All plumbing fixtures and fittings incident thereto for the following described plumbing fixtures shall meet the following standards:

(a) for sink and lavatory faucets, maximum flow shall not exceed three gallons of water per minute when tested in accordance with American National Standards Institute (ANSI) A112.18.1M; and

(b) for shower heads, maximum flow shall not exceed three gallons of water per minute when tested in accordance with ANSI A112.181M; and

(c) for water closets and associated flushing mechanism, maximum volume shall not exceed an average of one and six-tenths gallons per flushing cycle when tested in accordance with the hydraulic performance requirements of ANSI A112.19.2M and ANSI A112.19.6M; and

(d) for urinals and associated flushing mechanism, maximum flow shall not exceed one and one-half gallons of water per flush when tested in accordance with the hydraulic performance requirements of ANSI A112.19.2M and ANSI A112.19.6M.

*Unrevised copy for identification purposes only.
Sabrina Lee signed original.*

SECTION 2. REPEALER.

Any ordinance or part of ordinance conflicting with this ordinance be, and the same is hereby repealed insofar as the same affects this ordinance.

SECTION 3. This Ordinance shall become effective Five (5) days after the date of its adoption by the Board of Supervisors.

This Ordinance is hereby ordained and enacted into law this _____ day of _____, 1991, at a duly and legally convened meeting of the Board of Supervisors of the Township of Westfall.

WESTFALL TOWNSHIP BOARD OF SUPERVISORS

Chairman

Member

Member

Member

Member

ATTEST:

Township Secretary